

General Guidelines for Medical Marijuana Growing Operation

Detailed Mechanical plans prepared by a State of Michigan Licensed Mechanical Engineer or Architect must be submitted for Plan Review.

The following items must be addressed in the plans submitted:

1. Michigan Mechanical Code 2015

A: Section MMC 403 Ventilation Rate.

B: Section MMC 501.4 Pressure Equalization.

C: Section MMC 502.9.9 Ozone Gas Generators

D: Section MMC 502.1 General /Odors

E: Section MMC 510 Hazardous exhaust / CO2

2. International Fuel Gas Code 2015

A: Section IFGC 621 Unvented Appliances/ Ozone generators.

B: Section IFGC 402 Gas pipe sizing.

3. International Fire Code 2015

A: Section IFC 908.7 Carbon Dioxide Systems.

B: Section IFC 6005 Ozone Gas Generators.

4. ASHRAE 62-2013 Standard of Ventilation Levels.

5. ASHRAE 15-2013 Refrigeration Standards

6. Detail Carbon Monoxide and Carbon Dioxide Monitoring and alarm systems.