

**QUIZ ANSWERS**  
**CP-22-00105 – Gas Vents and Others**

1. Minimum rise on a vent connector shall be 1/8" per foot.

TRUE      **FALSE.** ~~-----~~ **Shall be ¼" per ft.**

2. Maximum horizontal run of an uninsulated connector is 80% of vent height.

TRUE      **FALSE** ~~-----~~ **Maximum is 75%**

3. 3" vent connectors are no longer approved under any circumstances.

TRUE      **FALSE**

4. If the table you need is not in the MRC, you may find it in the IFGC.

**TRUE**      FALSE

5. A vent connector may be up to 1 size larger than the vent in some cases.

**TRUE**      FALSE

6. Direct vent appliances may vent anywhere permitted by manufacturer

TRUE      **FALSE**

7. A power exhauster shall not vent within 7' of a property line

TRUE      **FALSE** ~~-----~~ **10'**

8. A power vent appliance shall be not less than 6' above walkways

TRUE      **FALSE** ~~-----~~ **7'**

9. In every case, a masonry chimney requires a liner when the furnace load is removed (high efficiency furnace is installed leaving only the water heater).

TRUE      **FALSE**

10. Appliances may never enter a vent at the same height.

TRUE      **FALSE**