

QUIZ ANSWERS FOR PLAN REVIEW BASED ON 2021 MMC & IFGC

1. How many copies of plans have to be submitted to the building department?
A. 2
2. How many days must building dept. hold plans for?
A. 180 days
3. What standards do plastic fittings be certified to?
A. NSF 14.
4. Condensate discharge cannot empty where?
B. Plumbing Vent stack directly.
5. Demand control ventilation cannot be set below what?
A. Outdoor air shall not fall below that determined from the area outdoor airflow rate per table 403.3.1.1
6. Class I hood clearance be reduced when of 18”?
C. When the hood is listed to UL 710 and installed manufacture’s clearances.
7. What type of ceiling radiation dampers require the system to be shut down.
A. Static type radiation dampers.
8. What type of heater is not allowed to be installed in a patient sleeping areas of a hospital?
C. Suspended-type unit heaters.
9. What type of appliances and equipment need to be listed and labeled?
C. Both A & B.
10. Fire dampers and smoke dampers shall not be installed in shafts that are required to maintain what?
A. Maintain continuous airflow upward where closure of the damper would result in the loss of airflow.