

Hazardous Materials Class Questions & Answers
True or False

1. Backflow protection is required on all potable water connections to prevent contamination from non-potable or hazardous sources.
2. Indirect waste with an air gap or air break is required when discharging liquids that may be hazardous or corrosive.
3. Hazardous chemical liquids may be discharged directly into the sanitary sewer without pretreatment.
4. Floor drains in areas storing flammable or combustible liquids must be protected from allowing those liquids to enter the sewer system.
5. Parking garage ventilation systems may operate intermittently when controlled by carbon monoxide (CO) or nitrogen dioxide (NO₂) detection.
6. CO detection must activate garage ventilation when concentrations reach 25 ppm.
7. Hazardous exhaust systems must discharge directly outdoors.
8. Ducts serving hazardous exhaust systems may not be combined with any other exhaust system.
9. Systems intended to control or mitigate hazardous materials must remain operational at all times.
10. The code official may require additional documentation, drawings, or hazard information if the nature of materials is unclear.